

CITY OF BROOK PARK, OHIO

P/C 11-16-21 Safety
CA PROX 12-7-21
1st R 12-7-21
2nd R 12-21-21
3rd R
V/C

ORDINANCE NO: 11232-2021

INTRODUCED BY: MAYOR GAMMELLA

AN ORDINANCE
AUTHORIZING THE MAYOR TO ENTER INTO A
CONTRACT WITH PROTEGIS FIRE & SAFETY FOR TWO FIRE ALARM SYSTEM
PANELS, AND DECLARING AN EMERGENCY

WHEREAS, the Service Director went out to bid for a vendor to replace the non-working fire alarm system at the Service garage; and

WHEREAS, the Service Director, along with the Fire Prevention Officer, obtained several quotes and selected Protegis Fire & Safety to be the lowest and/or best bidder.

NOW, THEREFORE, BE IT ORDAINED, by the Council of the City of Brook Park, State of Ohio, that:

SECTION 1: The Mayor is hereby authorized to enter into a contract, with Protegis Fire & Safety, for the purchase of two Fire Alarm System Panels, which are further described in Exhibit "A" (quote).

SECTION 2: The money needed for the aforesaid transaction shall be paid from Fund No. 401-422-52401, Capital Fund; theretofore appropriated for said purpose, and shall not exceed \$35,352.26.

SECTION 3: It is found and determined that all formal actions of this Council concerning and relating to the adoption of this Ordinance were adopted in an open meeting of this Council, and that all deliberations of this Council and of any of its committees that resulted in such formal action were in meetings open to the public in compliance with all legal requirements, including Section 121.22 of the Ohio Revised Code.

SECTION 4: This Ordinance is hereby declared to be an emergency measure immediately necessary for the preservation of the

public peace, health, safety and welfare of said City, and for the further reason to allow the City to purchase two fire alarm system panels; therefore provided this ordinance receives the affirmative vote of at least five (5) members elected to Council, it shall take effect and be in force immediately upon its passage and approval by the Mayor; otherwise, from and after the earliest period allowed by law.

PASSED: December 21, 2021 [Signature]
PRESIDENT OF COUNCIL

ATTEST: Michelle Blazak APPROVED: [Signature]
Clerk of Council MAYOR
12/21/21
DATE

CERTIFICATE
Michelle Blazak, Clerk of Council, of the City of Brook Park, Ohio, do hereby certify that the foregoing is a true and accurate copy of Ordinance/Resolution No. 11232-2021 passed on the 21st day of December 2021 by said council.
Michelle Blazak
Clerk of Council

I, Michelle Blazak, Clerk of Council for the City of Brook Park, State of Ohio, do hereby certify that there is no newspaper of general circulation in the municipality and that publication of the foregoing ordinances/resolutions was made by posting true copies at five of the most public places in said municipality as determined by Ordinance No. 4838-1975; location City Hall 6161 Engle Road, Police Station 17401 Holland Road, #2 Fire Station 22530 Ruple Parkway, #3 Fire Station 17401 Holland Road, Brook Park Library 6165 Engle Road, for a period of fifteen days.
commencing December 22, 2021
Michelle Blazak
MICHELLE BLAZIK
Clerk of Council

	Yea	Nay
Troyer	_____	_____
Mencini	_____	_____
Orcutt	_____	_____
Scott	_____	_____
Schmuck	<u>Noted</u>	_____
Poindexter	_____	_____
Salvatore	_____	_____

I HEREBY APPROVE THE WITHIN INSTRUMENT AS TO LEGAL FORM AND CORRECTNESS
[Signature]
DIRECTOR OF LAW



Area 2-Vehicle Maintenance Area

Scope of Work: Protegis to Provide Equipment, installation, Drawings, Programing and Testing

FMM-101	2	ADDRESSABLE MINI MODULE WITH FLASHSCAN
NBG-12LX	10	ADDRESSABLE NBG-12L PULL STATION; WITH FLASHSCAN.
B300-6	1	INTELLIGENT FLANGED MOUNTING BASE; 6" INCH; WHITE
FSCO-951	1	INTELLIGENT ADDRESSABLE CARBON MONOXIDE (CO) DETECTOR
B200S-WH	1	INTELLIGENT, ADDRESSABLE, PROGRAMMABLE PLUG-IN SOUNDER BASE
FSP-951	1	INTELLIGENT ADDRESSABLE PHOTO DETECTOR; WITH FLASHSCAN; WHITE
P2RL	15	HORN STROBE 2W RED WALL
P2RK	1	HORN/STROBE, 12/24 VOLT, RED, MULTI-CANDELA OUTDOOR, INCLUDES BACKBOX
PS1270	2	BATTERY 7AH
ANN-SB80KIT-B	1	BACKBOX KIT, SURFACE MOUNT, USED WITH N-ANN-80 , BLACK
N-ANN-80	1	REMOTE LCD ANNUNCIATOR MIMICS THE FACP DISPLAY, 80 CHARACTER DISPLAY.
ELOCK-FA	1	Circuit Breaker Lockout Kit
EELEC	1	ELECTRICAL EQUIPMENT
LABOR	1	Electrical Labor and Panel/DACT programming
TESTING	1	Pre/Acceptance Testing with AHJ
ENG	1	ENGINEERING/DRAWINGS***

Package Price \$ 14,228.89

Total Install Package Price: \$35,352.26

***Radio Monitoring \$742.00 Annually**

Terms C.O.D or NET 15 DAYS with approved credit. Approved payment schedule, PO, and signed contract is required before project start.

Please Note:

- *This quote is valid for 30 days from the date of this document*
- *This quote is for the above listed items only, any additional devices required will be at an additional cost*
- *This quote is dependent on AHJ approval.*
- *Monthly progressive billing for equipment purchased and services rendered.*
- *These prices do not reflect any sales tax. If applicable, sales tax will be added at time of billing.*
- *This quote does not include overtime hours, or site specific special safety requirements.*
- *This quote is based on a fluent construction schedule. Any delays or phasing of the project that will require additional site visits will be at an additional cost.*
- *Any work to be done in area's containing Asbestos will be halted until area is properly abated (by others)*
- *This quote does not include fire watch.*
- *Clean up of wiring debris due to installation only. No vacuuming, or dusting included.*
- *Walls, ceilings repairs or painting are not included.*
- *This quote does not include permit fees.*
- *This quote does not include phone lines or internet for the fire alarm equipment.*



This quote is based on the replacement of the existing panel and devices using existing wiring and device locations. Any additional work due to existing field conditions or AHJ additional requirements will be at additional cost.

PROTEGIS

Engineering is limited to equipment cut sheets and riser diagram only. No building drawings are included.

- *Engineering includes field voltage drops and battery check for as built.*

Please contact me if you should have any questions or need additional information. Thank you and we look forward to serving all of your fire protection needs.

Coriolan (Cory) Cioba SET

Fire Alarm Systems Designer/Estimator

Protegis Fire & Safety

T 216-377-3065

F 216-377-3066

C 330-388-4641



PROTEGIS
FIRE & SAFETY
Professional Proactive Protection

To accept this quote and terms contained within, please sign below and fax to us at 216.377.3066

Accepted By: _____

Printed Name: _____

Date of Acceptance: _____

PO#: _____