

P/C 4-19-22 SERVICE  
SP CA 4-20-22  
1st R \_\_\_\_\_  
2nd R \_\_\_\_\_  
3rd R \_\_\_\_\_  
B/C \_\_\_\_\_

CITY OF BROOK PARK, OHIO

ORDINANCE NO: 11256-2022

INTRODUCED BY: MAYOR ORCUTT & C/W

AN ORDINANCE  
AUTHORIZING THE MAYOR TO ENTER INTO A  
CONTRACT WITH BUCKEYE PUMPS, INC., TO PURCHASE  
FOUR LIFT STATION PUMPS, TWO CONTROL PANELS, AND TWO PRIMEX  
PRESSURE TRANSDUCERS,  
AND DECLARING AN EMERGENCY

WHEREAS, Council deems it necessary for the City to enter into a contract with Buckeye Pumps, Inc., for the purchase and installation of four Flyght/Xylem submersible pumps and the necessary equipment for the Fry/Richard and Calvin/Grosse pump stations.; and

NOW THEREFORE, BE IT ORDAINED, by the Council of the City of Brook Park, State of Ohio, that:

SECTION 1: That the Mayor is hereby authorized and directed to enter into a contract with Buckeye Pumps, Inc., for the purchase and installation of four dry pit submersible pumps, as set forth in Exhibit "A."

SECTION 2: The money needed for the aforesaid transaction shall be paid from fund #429, and in no event shall the total amount to be paid under said contract exceed \$86,962.00.

SECTION 3: It is found and determined that all formal actions of this Council concerning and relating to the adoption of this Ordinance were adopted in an open meeting of this Council, and that all deliberations of this Council and of any of its committees that resulted in such formal action were in meetings open to the public in compliance with all legal requirements, including Section 121.22 of the Ohio Revised Code.

SECTION 4: This Ordinance is hereby declared to be an emergency measure immediately necessary for the preservation of the public peace, health, safety and welfare of said City, and for the further reason that Council deems it necessary for the Mayor to enter into said agreement with undue delay; therefore provided (5)

members elected to Council, it shall take effect and be in force immediately upon its passage and approval by the mayor; otherwise, from and after the earliest period allowed by law.

PASSED: April 26, 2022

M. P. Kehring  
PRESIDENT OF COUNCIL

ATTEST: Carol Johnson  
Clerk of Council

APPROVED: Ed M. Ernst  
MAYOR

4-26-22  
DATE

CERTIFICATE

Carol Johnson, Clerk of Council, of the City of Brook Park, Ohio, do hereby certify that the foregoing is a true and accurate copy of Ordinance Resolution No. 11256-2022 passed on the 26 day of April 20 22 by said council.

Carol Johnson  
Clerk of Council


I, Carol Johnson, Clerk of Council for the City of Brook Park, State of Ohio, do hereby certify that there is no newspaper of general circulation in the municipality and that publication of the foregoing ordinances/resolutions was made by posting true copies at five of the most public places in said municipality as determined by Ordinance No. 4838-1975; location City Hall 6161 Engle Road, Police Station 17401 Holland Road, #2 Fire Station 22530 Ruple Parkway, #3 Fire Station 17401 Holland Road, Brook Park Library 6165 Engle Road, for a period of fifteen days.

commencing 4-29-22  
Carol Johnson  
CAROL JOHNSON  
Clerk of Council

	Yea	Nay
Troyer	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mencini	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Roberts	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Scott	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Coyne	<u>Absent</u>	<input type="checkbox"/>
Poindexter	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Salvatore	<input checked="" type="checkbox"/>	<input type="checkbox"/>

I HEREBY APPROVE THE WITHIN INSTRUMENT AS TO LEGAL FORM AND CORRECTNESS

[Signature]  
DIRECTOR OF LAW



DATE: APRIL 11, 2022

PRICE QUOTE BY: \_\_\_\_\_

COMPANY: BUCKEYE PUMP

DATE: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

ORDERED BY: B BEYER/B KALL

PHONE NO. \_\_\_\_\_

P.O.# \_\_\_\_\_

AREA WHERE PRODUCT USED: 429

VENDOR 2: \_\_\_\_\_

VENDOR 3: \_\_\_\_\_

AMOUNT	DESCRIPTION	DEPT.	PRICE EA.	TOTAL
4	FRY & RICHARD & KALVIN & GROSSE PUMP STSTAIONS FLYGHT/XYLEM SUBMERSIBLE PUMPS FOR BOTH PUMP STSTAIONS  ***SEE ATTACHED QUOTE**  **BOARD OF CONTROL**			\$ 86,962.00



buckeye pumps inc.

MAIN OFFICE	PH: (419) 468-7866
1311 Freese Works Place	FX: (419) 468-1460
Gallion OH 44833	
CINCINNATI OFFICE	PH: (513) 679-6100
24 East 76 <sup>th</sup> Street	FX: (513) 679-6101
Cincinnati OH 45216	

March, 3 2022

Quote # 27-030322-RJH

To: All Bidding Contractors

Attn: Bob Kall

Reference: City of Brookpark  
Location: Brookpark, Ohio  
Bid Date: N/A

Buckeye Pumps Inc. is pleased to provide pricing for the following equipment as required:

Fry/Richard, Kelvin/Grosse

**Lift Station Pumps (4 Pumps)**

Qty (2) – FLYGT/XYLEM Submersible Pumps Model NP 3127.091, rated for ?? GPM at ??' TDH. Pumps shall come with a standard 4" discharge. Pumps shall come with an 10 HP, 1800 RPM, 460/3/60 submersible explosion proof motors. Motor shall be air filled and have a 1.15 service factor rating; Thermal overloads shall be imbedded in the windings to provide overheating protection. Pumps shall come with a positively driven dual, tandem mechanical shaft seal system consisting of two seal sets, each having an independent spring. The lower primary seal, located between the pump and seal chamber, shall contain one stationary and one positive driven rotating corrosion and abrasion resistant tungsten-carbide ring. The upper secondary seal located between the seal chamber and the seal inspection chamber shall be a leakage-free seal. Moisture sensing probe shall be provided for detection of moisture on outer seal failure.

Qty (2) – FLYGT/XYLEM Submersible Pumps Model NP 3085.091, rated for ?? GPM at ??' TDH. Pumps shall come with a standard 4" discharge. Pumps shall come with an 3 HP, 1800 RPM, 460/3/60 submersible explosion proof motors. Motor shall be air filled and have a 1.15 service factor rating; Thermal overloads shall be imbedded in the windings to provide overheating protection. Pumps shall come with a positively driven dual, tandem mechanical shaft seal system consisting of two seal sets, each having an independent spring. The lower primary seal, located between the pump and seal chamber, shall contain one stationary and one positive driven rotating corrosion and abrasion resistant tungsten-carbide ring. The upper secondary seal located between the seal chamber and the seal inspection chamber shall be a leakage-free seal. Moisture sensing probe shall be provided for detection of moisture on outer seal failure.

**Two (2) Control Panel**

Engineered Panels: Fry and Richard 3HP, 10HP Kalvin and Grosse 3HP, 10HP

NEMA Type 4X - 304 Stainless Steel Enclosure, with back panel  
Aluminum Dead-front Inner Door  
Circuit breaker cutouts with mounting bracket  
Incoming Power Terminal Block

Current Monitor Relay  
 Incoming Power Lightning Arrestor  
 1 kVA Control Power Transformer with Primary Fuses  
 Control Power Circuit Breaker  
 3 - 15 Amp 1 Pole QOU Circuit Breaker  
 1 - Circuit Breaker( HDL) / 10 hp NEMA Motor Starter with Melting Alloy Overload  
 1 - Circuit Breaker( HDL) / 3 hp NEMA Motor Starter with Melting Alloy Overload  
 LevelView Primary Controller  
 DPC-4F Secondary Controller  
 2 - 22mm Hand Off Auto Switch  
 2 - 22mm Run Pilot Light  
 2 - Elapsed Time Meter  
 LED Alarm Light  
 Horn Audible Alarm  
 22mm Silence Pushbutton  
 PumpWatch Gateway/ panel mount with one year cellular service  
 Engraved Nameplates  
 UL Label 508  
 Self Laminating Wire Numbers  
 Control Relays as required  
 Terminal Blocks and Ground Lugs as Required

**Two (2) Primex Pressure Transducer With 100' Cord**

**Buckeye Pumps Will Use The Current Air In Take Pipe To Run The Pump Cables. Panel Should**  
**Roughly**  
**Be 30"x36"x12, and Panel Will Be Mounted On The Pole.**

Fourteen (4) Female Power Cable Adapters  
 Fourteen (4) Male Power Cable Adapters  
 Eight (8) Handles For Adapters

**Total Price for above items.....\$86,962.00**

- Startup service is provided.
- Freight is included.
- Submittals available in 3-4 weeks after receipt of order.
- Delivery 10-12 weeks after receipt of approved submittals.
- Prices in this proposal are good for 90 days.
- Net due: 30 days with approved credit.
- No retainage withheld for delivered material only.
- All material remains the property of BPI until paid for in full.
- 2% monthly service charge after 30 days.

**Quote excludes: Any Traffic Control Needed. Should Be Handled By The City of Brookpark if Needed.**

I understand that the terms of this proposal are final, and no other terms or actions proposed by the customer – including contracts or purchase orders – are applicable without the signed approval of the authorized agent for Buckeye Pumps Inc. (BPI). I also understand that BPI is under no obligation to produce and/or deliver the materials described in this proposal until it is signed by the customer.

Upon my signature, this proposal and the terms within will act as a sales contract between Buckeye Pumps Inc. and the customer, and acts as a request for the Notice of Commencement for the Project.

Signature of Authorized Agent for the Customer: \_\_\_\_\_

Printed Name: \_\_\_\_\_

Company Name & Address: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Fax Number: \_\_\_\_\_

Date: \_\_\_\_\_

Authorized Agent for BPI: \_\_\_\_\_

Ryan Hoepf  
Buckeye Pumps  
419-566-0202  
[rhoepf@buckeyepumps.com](mailto:rhoepf@buckeyepumps.com)