

P/C 10-6-20 SERVICE
CA 10-13-20
1st R 11-20-20
2nd R _____
3rd R _____
B/C _____

CITY OF BROOK PARK, OHIO

ORDINANCE NO: 11169-2020

INTRODUCED BY: MAYOR GAMMELLA

AN ORDINANCE
AUTHORIZING THE MAYOR TO ENTER INTO A
CONTRACT WITH NORTH SHORE PUMP & EQUIPMENT COMPANY,
WITHOUT PUBLIC BIDDING, FOR THE PURCHASE AND INSTALLATION OF
TWO GRUNDFOS DRY SUBMERSIBLE PUMPS,
AND THE REMOVAL OF EXISTING PUMPS,
AND DECLARING AN EMERGENCY

WHEREAS, Council deems it necessary for the City to enter into a contract with an exclusive dealer for the purchase and installation of two (2) Grundfos 12 HP SEI.30A40 Submersible pumps and the other necessary equipment for the installation thereof, and removal of existing two (2) pumps at the Sylvia Pump Station; and

WHEREAS, said equipment is of such a highly specialized nature, requiring the exercise of peculiar skill and aptitude, and that said contract is properly deemed excepted from the bidding requirements ordinarily associated with the letting of public contracts.

NOW THEREFORE, BE IT ORDAINED, by the Council of the City of Brook Park, State of Ohio, that:

SECTION 1: That the Mayor is hereby authorized and directed to enter into a contract with North Shore Pump & Equipment Co., for the purchase and installation of two dry pit submersible pumps and removal of existing pumps, as set forth in Exhibit "A."

SECTION 2: The money needed for the aforesaid transaction shall be paid from funds theretofore appropriated for said purposes, Capital Fund 429; provided that, in no event shall the total amount to be paid under said contract shall not exceed \$66,718.00.

SECTION 3: It is found and determined that all formal actions of this Council concerning and relating to the adoption of this Ordinance were adopted in an open meeting of this Council, and

that all deliberations of this Council and of any of its committees that resulted in such formal action were in meetings open to the public in compliance with all legal requirements, including Section 121.22 of the Ohio Revised Code.

SECTION 4: This Ordinance is hereby declared to be an emergency measure immediately necessary for the preservation of the public peace, health, safety and welfare of said City, and for the further reason that Council deems it necessary for the Mayor to enter into said agreement with undue delay; therefore provided (5) members elected to Council, it shall take effect and be in force immediately upon its passage and approval by the mayor; otherwise, from and after the earliest period allowed by law.

PASSED: October 20, 2020 M. P. Vecchio
PRESIDENT OF COUNCIL

ATTEST: Michelle Blazak APPROVED: [Signature]
Clerk of Council MAYOR

10/21/2020
DATE

CERTIFICATE
Michelle Blazak, Clerk of Council, of the City of Brook Park, Ohio, do hereby certify that the foregoing is a true and accurate copy of Ordinance/Resolution No. 11169-2020 passed on the 20th day of October 2020 by said council.
Michelle Blazak
Clerk of Council

I, Michelle Blazak, Clerk of Council for the City of Brook Park, Ohio, do hereby certify that there is no newspaper of general circulation in the municipality and that publication of the foregoing ordinance/resolutions was made by posting true copies at five of the most public places in said municipality as determined by Ordinance No. 43-10-01 at the following locations: City Hall 6161 Engle Road, Police Station 17401 Holladay Road, #2 Fire Station 22530 Ruple Parkway, #3 Fire Station 17401 Holladay Road, Brook Park Library 6165 Engle Road, for a period of fifteen days.
Commencing October 20, 2020
Michelle Blazak
MICHELLE BLAZAK
Clerk of Council

	Yea	Nay
Troyer	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Mencini	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Orcutt	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Scott	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Schmuck	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Poindexter	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Salvatore	<input checked="" type="checkbox"/>	<input type="checkbox"/>

I HEREBY APPROVE THE WITHIN INSTRUMENT AS TO LEGAL FORM AND CORRECTNESS
[Signature]
DIRECTOR OF LAW



North Shore Pump & Equipment Co.

2535 Center Street Cleveland, Ohio 44113
Telephone: 216-622-1890 Fax: 216-622-1894
Email: nspumpco@sbcglobal.net

September 1, 2020

City of Brookpark
Attn: Randy Garner
Reference: Ball Field Pump Station

Randy,

We wish to offer the following pumps and services to replace (2) existing Yeomans VPM Pumps.

Pumps sized for 600gpm @27'
New Pumps will deliver approx. 900gpm

Package to include:

- (2) Grundfos 12HP SEI.30A40 Dry Pi Submersibles
- (2) Pedestal stands
- Custom fabricated pipe and elbows to install into existing system
- Supply and install (2) 6" inlet valves, (1) 4" check valve, (2) 4" OSY Isolation valves.
- Wire pumps to existing Grundfos Controller
- Startup pumps

Package Net.....\$66,718.00

- ~ Pumps will be installed in (2) separate mobilizations.
- ~ City is responsible for pumping down wet well in order to install suction valves.

Thank you for the opportunity to quote.

Scott Bloomhuff